

CERTIFICATE OF COMPLIANCE

Certificate Number 20170413-S35687
Report Reference S35687-20170412
Issue Date 2017-APRIL-13

Issued to: Foremost Early Detection Partners Ltd
3 Yongjie North Rd. Haidian District
Beijing
100094 CHINA

**This is to certify that
representative samples of**

SMOKE-AUTOMATIC FIRE DETECTOR ACCESSORIES
FMST FXV Series Aspirating Smoke Detection System, air
sampling type, Models FMST-FXV-11E, FMST-FXV-
11E/CN, FMST-FXV-22E, FMST-FXV-22E/CN, FMST-FXV-
33E, FMST-FXV-33E/CN, FMST-FXV-44E, and FMST-
FXV-44E/CN.
Must be used with a UL 1481 Listed power supply and UL
864 Listed fire alarm control unit.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 268, Smoke Detectors for Fire Alarm Systems
ANSI/UL 268A, Smoke Detectors for Duct Application

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

